

TECHNICAL SERVICE REPORT

Water Analysis


Customer:	Location:	Date:	PO#:
Chick-fil-A	# 1449	2/21/08	304787
Address:		Tested By:	
4050 Dowlen Rd. Beaumont TX 77706		AR	
Phone:	Email:	Selecto Contact:	

Recommendation:	
------------------------	--

ANALYTICAL RESULTS

Evaluation of:	Unfiltered Water Sample	Filtered Water Sample	Recommended Max Levels
Fluoride, ppm	0.3	0.3	2 ppm
Chloride, ppm	70	48	250 ppm
Nitrite, ppm	ND	ND	1 ppm as N
Nitrate, ppm	0.1	0.1	10 ppm as N
Sulfate, ppm	2.3	2.2	250 ppm
Sodium, ppm	113	98	250 ppm
Chloramine	ND	ND	.5 ppm
Chlorine, ppm	Detected	Detected	Detectable
Alkalinity, ppm	215	215	150 ppm
Total Dissolved Solids, ppm	280	240	500 ppm
Hardness, ppm	32	32	100 ppm
pH	7.5	7.5	6.5 – 8.5 ppm
Turbidity	0.30	0.30	.05 NTU

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



SELECTO SCIENTIFIC
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

www.selectoinc.com
sales@selectoinc.com