

## TECHNICAL SERVICE REPORT

### Water Analysis

<b>Customer:</b>	<b>Location:</b>	<b>Date:</b>	<b>PO#:</b>
Chick-fil-A	# 1021	2/20/08	304925
<b>Address:</b>		<b>Tested By:</b>	
800 Walnut Creek Dr. Mansfield, TX 76063		AR	
<b>Phone:</b>	<b>Email:</b>	<b>Selecto Contact:</b>	

<b>Recommendation:</b>	
------------------------	--

### ANALYTICAL RESULTS

Evaluation of:	Hand Sink Water Sample	Salad Sink Water Sample	Recommended Max Levels
Fluoride, ppm	0.9	0.8	2 ppm
Chloride, ppm	27	26	250 ppm
Nitrite, ppm	ND	ND	1 ppm as N
Nitrate, ppm	0.4	0.4	10 ppm as N
Sulfate, ppm	50	51	250 ppm
Sodium, ppm	30	28	250 ppm
Chloramine	Detected	Detected	.5 ppm
Chlorine, ppm	Detected	Detected	Detectable
Alkalinity, ppm	100	105	150 ppm
Total Dissolved Solids, ppm	180	180	500 ppm
Hardness, ppm	110	113	100 ppm
pH	7.2	7.3	6.5 – 8.5 ppm
Turbidity	0.00	0.00	.05 NTU

The information supplied is believed to be accurate and is only indicative of the water tested. The testing laboratory is not state certified.



**SELECTO SCIENTIFIC**  
INCORPORATED

3980 Lakefield Court • Suwanee, GA 30024 • 678.475.0799 • 800.635.4017

[www.selectoinc.com](http://www.selectoinc.com)

[sales@selectoinc.com](mailto:sales@selectoinc.com)